






# COOL ROOF RATING COUNCIL NOTIFICATION OF PRODUCT RATING

	<b>Notification Provided By:</b> <b>CoolRoofRatingCouncil</b> 2435 N. Lombard St. Portland, OR 97217	<b>Notification Provided To:</b> <b>ProgressiveMaterials,LLC.</b> 540 central court, new albany, IN 47150
---	---	--


<b>Product</b>	<b>HS-3201</b>	<b>Product Type:</b>	Coating
<b>Brand:</b>		<b>Initial SRI:</b>	113
<b>Product</b>	<b>White High Solids Low VOC Silicone Roof</b>	<b>3 Year SRI:</b>	90
<b>Model:</b>	<b>Coating</b>	<b>Slope Types:</b>	Low, Steep
<b>Company:</b>	<b>Progressive Materials, LLC.</b>	<b>Color:</b>	Bright White
<b>Contact Name:</b>	b.j. steele		
<b>Telephone:</b>	8126973535		

	<b>Initial</b>	<b>Weathered</b>	
	<b>Solar Reflectance</b>	<b>0.89</b>	<b>0.73</b>
	<b>Thermal Emittance</b>	<b>0.90</b>	<b>0.88</b>
	Rated Product ID	1158-0001	
	Licensed Manufacturer	1158	
Classification	Standard Product		
<p>Cool Roof Rating Council ratings are determined for a fixed set of conditions, and may not be appropriate for determining seasonal energy performance. The actual effect of solar reflectance and thermal emittance on building performance may vary.</p> <p>Manufacturer of product stipulates that these ratings were determined in accordance with the applicable Cool Roof Rating Council procedures.</p>			


The Cool Roof Rating Council (CRRC), an ISO 17065 accredited organization, has reviewed the test results data provided by a CRRC-approved ISO 17025 testing laboratory and has determined this roofing product meets the requirements described in the ANSI/CRRC S100 Standard and the CRRC-1 Program Manual. This Notification of Rating is subject to all terms and conditions of the Licensee Agreement and the documents incorporated therein by reference. This document must be reproduced in its entirety.

			04/04/2018
Technical Reviewer	Application Reviewer	Management Approval	Date

# COOL ROOF RATING COUNCIL NOTIFICATION OF PRODUCT RATING




	<b>Notification Provided By:</b> <b>CoolRoofRatingCouncil</b> 2435 N. Lombard St. Portland, OR 97217	<b>Notification Provided To:</b> <b>ProgressiveMaterials,LLC.</b> 540 central court, new albany, IN 47150
---	---	--

<b>Product</b>	<b>LS-2201</b>	<b>Product Type:</b>	Coating
<b>Brand:</b>		<b>Initial SRI:</b>	110
<b>Product</b>	<b>LS-2201 Low Solids Silicone Roof</b>	<b>3 Year SRI:</b>	90
<b>Model:</b>	<b>Coating</b>	<b>Slope Types:</b>	Low, Steep
<b>Company:</b>	<b>Progressive Materials, LLC.</b>	<b>Color:</b>	Bright White
<b>Contact Name:</b>	b.j. steele		
<b>Telephone:</b>	8126973535		


	<b>Initial</b>	<b>Weathered</b>	
	<b>Solar Reflectance</b>	<b>0.87</b>	<b>0.73</b>
	<b>Thermal Emittance</b>	<b>0.90</b>	<b>0.90</b>
	Rated Product ID	1158-0002	
	Licensed Manufacturer	1158	
Classification	Standard Product		
<p>Cool Roof Rating Council ratings are determined for a fixed set of conditions, and may not be appropriate for determining seasonal energy performance. The actual effect of solar reflectance and thermal emittance on building performance may vary.</p> <p>Manufacturer of product stipulates that these ratings were determined in accordance with the applicable Cool Roof Rating Council procedures.</p>			

The Cool Roof Rating Council (CRRC), an ISO 17065 accredited organization, has reviewed the test results data provided by a CRRC-approved ISO 17025 testing laboratory and has determined this roofing product meets the requirements described in the ANSI/CRRC S100 Standard and the CRRC-1 Program Manual. This Notification of Rating is subject to all terms and conditions of the Licensee Agreement and the documents incorporated therein by reference. This document must be reproduced in its entirety.


The Notification of Rating certificate for the approved initial ratings is valid until an updated certificate is issued by the CRRC that includes the approved three-year aged ratings. The certificate with the approved three-year aged ratings is valid until either the CRRC or Licensee removes the product from the CRRC Rated Products Directory.

 _____ Technical Reviewer	 _____ Application Reviewer	 _____ Management Approval	12/31/2017 _____ Date
--	--	--	-----------------------------

# COOL ROOF RATING COUNCIL NOTIFICATION OF PRODUCT RATING




	<b>Notification Provided By:</b> <b>CoolRoofRatingCouncil</b> 2435 N. Lombard St. Portland, OR 97217	<b>Notification Provided To:</b> <b>ProgressiveMaterials,LLC.</b> 540 central court, new albany, IN 47150
---	---	--

<b>Product Brand:</b> Pro Eco Sil	<b>Product Type:</b> Coating
<b>Product Model:</b> HS3201-HB	<b>InitialSRI:</b> 113
<b>Company:</b> Progressive Materials,LLC.	<b>3Year SRI:</b> 90
<b>Contact Name:</b> b.j. steele	<b>Slope Types:</b> Low, Steep
<b>Telephone:</b> 8126973535	<b>Color:</b> Bright White

	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="border-bottom: 1px solid black;"></th> <th style="border-bottom: 1px solid black;">Initial</th> <th style="border-bottom: 1px solid black;">Weathered</th> </tr> </thead> <tbody> <tr> <td><b>Solar Reflectance</b></td> <td><b>0.89</b></td> <td><b>0.73</b></td> </tr> <tr> <td><b>Thermal Emission</b></td> <td><b>0.90</b></td> <td><b>0.88</b></td> </tr> <tr> <td>Rated Product ID</td> <td colspan="2">1158-0003</td> </tr> <tr> <td>Licensed Manufacturer</td> <td colspan="2">1158</td> </tr> <tr> <td>Classification</td> <td colspan="2">Standard Product</td> </tr> </tbody> </table>		Initial	Weathered	<b>Solar Reflectance</b>	<b>0.89</b>	<b>0.73</b>	<b>Thermal Emission</b>	<b>0.90</b>	<b>0.88</b>	Rated Product ID	1158-0003		Licensed Manufacturer	1158		Classification	Standard Product	
	Initial	Weathered																	
<b>Solar Reflectance</b>	<b>0.89</b>	<b>0.73</b>																	
<b>Thermal Emission</b>	<b>0.90</b>	<b>0.88</b>																	
Rated Product ID	1158-0003																		
Licensed Manufacturer	1158																		
Classification	Standard Product																		
<p style="font-size: small;">Cool Roof Rating Council ratings are determined for a fixed set of conditions, and may not be appropriate for determining seasonal energy performance. The actual effect of solar reflectance and thermal emittance on building performance may vary.</p> <p style="font-size: small;">Manufacturer of product stipulates that these ratings were determined in accordance with the applicable Cool Roof Rating Council procedures.</p>																			

The Cool Roof Rating Council (CRRC), an ISO 17065 accredited organization, has reviewed the test results data provided by a CRRC-approved ISO 17025 testing laboratory and has determined this roofing product meets the requirements described in the ANSI/CRRC S100 Standard and the CRRC-1 Program Manual. This Notification of Rating is subject to all terms and conditions of the Licensee Agreement and the documents incorporated therein by reference. This document must be reproduced in its entirety.

The Notification of Rating certificate for the approved initial ratings is valid until an updated certificate is issued by the CRRC that includes the approved three-year aged ratings. The certificate with the approved three-year aged ratings is valid until either the CRRC or Licensee removes the product from the CRRC Rated Products Directory.

 _____ Technical Reviewer	 _____ Application Reviewer	 _____ Management Approval	06/02/2018 _____ Date
--	--	--	-----------------------------